

# Water Quality Report for Pemberton Early Childhood Education Center

100 Arney's Mount Road  
Pemberton, N.J. 08068

As a result of testing Pemberton Early Childhood Center drinking water, required by the New Jersey Department of Environmental Protection, the following chart provides sampling results for those contaminants detected in our drinking water.

Contaminant	MCL / AL / RUL*	Level Detected	Units	Exceeded (Yes or No)
Lead	15.0 ug/l	Result at 90 <sup>th</sup> % 10.9 UG/L	ug/l	NO
Copper	1.3 mg/l	Result at 90 <sup>th</sup> % 0.7 mg/l	mg/l	NO
Fluoride	4.0 mg/l	0.1 mg/l	mg/l	NO
TTHM	80.0 mg/l	9.0 mg/l	mg/l	NO
Barium	2.0 mg/l	0.1 mg/l	mg/l	NO
Chromium	6.0 ug/l	0.9 ug/l	ug/l	NO
Cyanide	100.0 ug/l	2.3 ug/l	ug/l	NO
Combined Radium	5.0 pci/l	1.0 pci/l	pci/l	NO

\*MCL = Maximum Contaminant Level; AL = Action Level; RUL = Recommended Upper Limit

For additional information on drinking water please refer to the NJDEP, Division of Water Supply & Geoscience website at <https://www.nj.gov/dep/watersupply/> or the United States Environmental Protection Agency's website at <https://www.epa.gov/safewater/>

Questions may be directed to Mr. Dean Adams at 609-893-8141.

**Note:** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).